

SOLARIXPEDIA

CPR: What You Will Find on the CPR Label of Solarix Cables

CPR LABEL FOR SOLARIX INSTALLATION CABLES

- Each Solarix installation cable is properly marked with a **CPR label** in accordance with the EU Regulation **No. 305/2011** with mandatory data, both on the packaging (i.e. reel or box) and on the cable itself (selected data)
- All required documents - i.e. **Declaration of Performance (DoP)** and **AVCP 1+** certificates (for B2ca and Cca cables) - are available for customers to **download at** www.solarix.cz

CE MARKING

Solarix cable complies with the harmonized standard listed on the label

NOTIFIED BODY

Number of the notified body that carried out the conformity assessment with the harmonised standard

MANUFACTURER

Name and registered address of the manufacturer

YEAR OF CE MARKING ATTACHMENT

Last two digits of the year in which the CE marking was first affixed to the product

LABELLING AND DESCRIPTION

Solarix installation cable type designation and its description including packaging

EAN CODE

Unique product barcode in the EAN system, type EAN-13

CONTACT INFORMATION

Contact for further information about the product

PRODUCT NO.

Solarix installation cable order number

BATCH NUMBER

Solarix installation cable batch number

DOP NO.

Declaration of Performance number, available for download at www.solarix.cz (this document is issued by the manufacturer)

HARMONIZED STANDARD

Marking of the harmonized standard against which the Solarix cable has been assessed by the notified body

INTENDED USE

Intended use of the Solarix installation cable

REACTION TO FIRE

Reaction to fire class determined by cable assessment by the notified body



DANGEROUS SUBSTANCES

Information on the release of hazardous substances